

Architect's Supplemental Instructions

Project:	DORM A RENOVATIONS AND ADDITIONS	ASI No.	04
Owner:	NJ Jersey's Fireman's Home 565 Lathrop Avenue Boonton, NJ 07005	Date of Issuance	9/16/2019
Architect:	Spiezle Architectural Group, Inc. 1395 Yardville Hamilton Square Road Suite 2A Hamilton, NJ 08691	Architect No.	17H025

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents.

Description

1. Structural Memorandum

Issued By the Architect:

Steven Leone
Spiezle Architectural Group

Harrison-Hamnett, P.C.
Consulting Structural Engineers

Principals

John N. Harrison, P.E.
Donald M. Hamnett, P.E.
Daryl J. Dearolf, P.E.
Mark W. Gaffney, P.E.
Forrest W. Harrison, P.E.

Senior Associates

Craig M. Block
William J. Bocchieri, P.E.
Richard C. Miller, P.E.

Associates

Richard S. Poll, P.E.
Steven J. Renaud, P.E.
Ian W. Slatas, P.E.

MEMORANDUM

To: Mr. Steve Leone
Mr. Todd Waskowitz
The Spiezle Architectural Group, Inc.

From: Donald M. Hamnett, P.E.
Harrison-Hamnett, P.C.

Date: September 9, 2019


Re: NJ Firemen's Home
Column Reinforcement

Our office has determined that the reinforcement of Columns EBE1 and EBE5, noted on Drawing S1.1, may be omitted.

This will result in only four (4) columns requiring reinforcement, not six (6), as noted on the plans.

Also, the reinforcing may extend to the underside of the existing cross bracing connection and begin above the connection.

If you have any questions, please do not hesitate to contact our office.



Donald M. Hamnett, P.E.
N.J.P.E. # 18976

cc: Kathleen Hogan, Spiezle Architectural Group
Forrest Harrison, Harrison-Hamnett, P.C.
Jon Howarth, Harrison-Hamnett, P.C.